

MUNICIPAL UTILITIES BOARD OF THE CITY OF ALBERTVILLE  
 SPECIFICATIONS FOR RESIDENTIAL OVERHEAD SERVICE  
 REQUIREMENTS 200 AMP

Note #1: Use Penetrox On All Aluminum Connections

Note #2: Do not Install Shielded Entrance Cable in Conduit (Gray Insulation)

Note #3: Must have a disconnect

Disconnect	Copper Wire	Aluminum Wire	Conduit Size
100 Amp	#2	#2	2 1/2"
200 Amp	3/0	4/0	2 1/2"
Neutral	1/2 Size of Hotleg	1/2 Size of Hotleg	
Ground	#4 Bare Copper		

